

DESCRIPCIÓN DEL TEST / TEST DESCRIPTION				NORMA / STANDARD	VALOR DEL TEST / TEST VALUE	EVALUACIÓN / EVALUATION
<b>NATURAL · OAK · WALNUT</b>						
<b>FORMATO / SIZE</b>		30X150 CM RC				
<b>GRUPO / GROUP</b>		B1a				
<b>TIPO / TYPE</b>		PORCELANICO / PORCELAIN TILE				
DESCRIPCIÓN DEL TEST / TEST DESCRIPTION				NORMA / STANDARD	VALOR DEL TEST / TEST VALUE	EVALUACIÓN / EVALUATION
<b>ABSORCIÓN DE AGUA / WATER ABSORPTION</b>				UNE-EN-ISO 10545-3	Ev ≤ 0,5%	CUMPLE / COMPLIES
<b>FUERZA DE ROTURA / BREAKING STRENGTH</b>				UNE-EN-ISO-10545-4	≥ 1300 N	CUMPLE / COMPLIES
<b>RESISTENCIA A LA FLEXIÓN / MODULUS OF RUPTURE</b>				UNE-EN-ISO-10545-4	≥ 35 N/mm2	CUMPLE / COMPLIES
<b>ABRASIÓN SUPERFICIAL / SURFACE ABRASION</b>				UNE-EN-ISO-10545-7	VALOR DECLARADO / DECLARED VALUE	NATURAL PEI IV OAK PEI III WALNUT PEI III
<b>RESISTENCIA AL CUARTEO / CRAZING RESISTANCE</b>				UNE-EN-ISO-10545-11	REQUERIDO / REQUESTED	CUMPLE / COMPLIES
<b>RESISTENCIA AL LA HELADA / FROST RESISTANCE</b>				UNE-EN-ISO-10545-12	REQUERIDO / REQUESTED	CUMPLE / COMPLIES
<b>RESISTENCIA A LAS MANCHAS / RESISTANCES TO STAINS</b>				UNE-EN-ISO-10545-14	MÍNIMO CLASE 3 / MINIMUM CLASS 3	CUMPLE / COMPLIES
<b>RESISTENCIA QUÍMICA / CHEMICAL RESISTANCE</b>	PRODUCTOS DOMESTICOS Y DE PISCINA / HOUSEHOLD CHEMICALS AND SWIMMING POOLS SALTS			UNE-EN-ISO-10545-13	MÍNIMO CLASE B / MINIMUM CLASS B	CUMPLE / COMPLIES
	ÁCIDOS A BAJA CONCENTRACIÓN / LOW CONCENTRATION ACIDS			UNE-EN-ISO-10545-13	VALOR DECLARADO / DECLARED VALUE	MÍNIMO CLASE LB / MINIMUM CLASS LB
	BASES A BAJA CONCENTRACIÓN / LOW CONCENTRATION OF ALKALIS			UNE-EN-ISO-10545-13	VALOR DECLARADO / DECLARED VALUE	MÍNIMO CLASE LB / MINIMUM CLASS LB
<b>RESISTENCIA AL DESLIZAMIENTO / SLIP RESISTANCE</b>	PÉNDULO / PENDULUM			UNE-41901 EX		CLASE 1 / CLASS 1
	ÁNGULO CRÍTICO DESLIZAMIENTO (RAMPA) / CRITICAL ANGLE OF SLIP (INCLINED PLATFORM)			DIN 51130:2014-5		R9
<b>RESISTENCIA AL RAYADO / HARDNESS (MOHS)</b>				EN-101	VALOR DECLARADO / DECLARED VALUE	MÍNIMO 3 / MINIMUM 3